

Test Verification of Conformity

Verification Number: 2401B1675SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

| | |
|---|---|
| Applicant Name & Address: | Shenzhen Lvyou Energy Technology Co., Ltd 103-104, Building 12, Dawangshan 2 nd Industrial Zone, Shajing, Baoan District, Shenzhen, Guangdong, China |
| Product Description: | Micro Inverter |
| Ratings & Principle Characteristics: | See Appendix (Specifications table) |
| Models/Type References: | See Appendix (Specifications table) |
| Brand Name: | N/A |
| Relevant Standards: | VDE-AR-N 4105:2018 in conjunction with DIN VDE V 0124-100 :2020 |
| Verification Issuing Office Name & Address: | Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China |
| Date of Tests: | 2023-09-04 to 2023-12-30 |
| Test Report Number(s): | 2401B1675SHA-001 |
| Additional information in Appendix. | |


Signature

Name: Max Jin

Position: General Manager

Date: 2024-03-06

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2401B1675SHA-V1

Manufacturer: Same as applicant

| Specifications table | |
|-------------------------------|---|
| Model | ES-800 |
| Input: | |
| Vmax PV (Vdc) | 55 |
| Isc PV (absolute Max.) (A) | 24 |
| Number MPP trackers | 2 |
| Number input strings | 2 |
| Max. PV input current(A) | 14*2 |
| MPPT voltage range (Vdc) | 16 to 55 |
| Output | |
| Normal Voltage(V) | <input checked="" type="checkbox"/> 1/N/PE 230Vac <input type="checkbox"/> 3 φ /N/PE 230/400Vac |
| Frequency (Hz) | <input checked="" type="checkbox"/> 50 Hz <input checked="" type="checkbox"/> 60Hz |
| Current (Max. continuous) (A) | 3.13 |
| Power rating (W) | 720 |
| Power Rating (VA) | 720 |
| Power factor /rated | ≥0.99 |
| others | |
| Protective class | Class I |
| Ingress protection (IP) | IP 67 |
| Temperature (°C) | -40° C to +65° C |
| Inverter Isolation | <input type="checkbox"/> Non-isolated <input checked="" type="checkbox"/> High frequency isolated |
| Overvoltage category | OVC III (AC Main), OVC II (PV) |
| Weight (kg) | 1.8 |
| Dimensions (WxHxD) (mm) | 22.3 x 4.3 x 23 |

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Annex E4: Verification of Conformity for power generation units

| | | |
|--|---|--------|
| Verification of Conformity for power generation units | No.: 2401B1675SHA-V1 | |
| Manufacturer | Shenzhen Kingsource Technology Co., Ltd. 4F, Building 6, Antuoshan High-tech Industrial Park, Xinsha Road, Shajing Street, Bao'an District, Shenzhen, Guangdong, China | |
| Type power generation unit | Micro Inverter | |
| Model | | ES-800 |
| Assessment values | Max. active power $P_{E_{max}}$ | 720 W |
| | Max. apparent power $S_{E_{max}}$ | 720 VA |
| | Rated voltage | 230Vac |
| Rated values | Rated current (AC) I_r | 3.13A |
| | Initial short-circuit AC current | 24A |
| Network connection rules | VDE-AR-N 4105 "Power generation systems connected to the low-voltage network" Technical minimum requirements for connection and parallel operation of power generation systems connected to the low voltage network | |
| Firmware version | KS-01 | |
| | | |

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Annex E.5 Test report “Network interactions” for power generation units

| | | | | | | |
|--|--|--------|-----|-----|-----|----------------------|
| Extract from the test report on the certificate of units | 2401B1675SHA-001 | | | | | |
| Manufacturer: | Shenzhen Kingsource Technology Co., Ltd. 4F, Building 6, Antuoshan High-tech Industrial Park, Xinsha Road, Shajing Street, Bao'an District, Shenzhen, Guangdong, China | | | | | |
| Manufacturer indications: | System type | ES-800 | | | | |
| | Max. active power $P_{E_{max}}$ | 720 W | | | | |
| | Rated voltage | 230Vac | | | | |
| Measurement period | 2023-09-04 to 2023-12-30 | | | | | |
| Rapid voltage changes | | | | | | N/A |
| Connection without provisions (regarding the primary energy carrier) | | | | | | $k_f = 0.12$ |
| Most adverse case when switching between generator levels | | | | | | N/A |
| Connection at nominal conditions (of the primary energy carrier) | | | | | | $k_f = 1.00$ |
| Disconnection at rated power | | | | | | $k_f = 0.98$ |
| Worst value of all switching operations | | | | | | $k_{f_{max}} = 1.02$ |
| Flicker | Angle of network impedance Ψ_k : | 32° | 30° | 50° | 70° | 85° |
| | Long-term flicker strength P_{lt} : | 0.26 | N/A | N/A | N/A | N/A |
| | Initial flicker factor c_ψ : | N/A | N/A | N/A | N/A | N/A |

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

E.5 Test report “Network interactions” for power generation units

| (5.2.4) | TABLE: Harmonics | | | | | | | | | | | P |
|----------------------|------------------|------|------|------|------|------|------|------|------|------|------|-------|
| Harmonics | | | | | | | | | | | | |
| P/P _n [%] | 0 | 10 | 20 | 30 | 40 | 50 | 60 | 70 | 80 | 90 | 100 | Limit |
| Order No. | I/In [%] | | | | | | | | | | | |
| 2 | 0.73 | 0.37 | 0.35 | 0.34 | 0.36 | 0.37 | 0.38 | 0.34 | 0.41 | 0.44 | 0.56 | -- |
| 3 | 0.58 | 0.98 | 0.36 | 0.29 | 0.23 | 0.21 | 0.17 | 0.22 | 0.19 | 0.21 | 0.30 | -- |
| 4 | 0.47 | 0.21 | 0.19 | 0.21 | 0.16 | 0.15 | 0.16 | 0.13 | 0.12 | 0.17 | 0.27 | -- |
| 5 | 0.56 | 1.16 | 0.69 | 0.59 | 0.53 | 0.51 | 0.44 | 0.34 | 0.32 | 0.39 | 0.50 | -- |
| 6 | 0.56 | 0.18 | 0.03 | 0.05 | 0.07 | 0.07 | 0.08 | 0.09 | 0.09 | 0.03 | 0.07 | -- |
| 7 | 0.53 | 0.74 | 0.56 | 0.44 | 0.39 | 0.38 | 0.42 | 0.40 | 0.36 | 0.28 | 0.18 | -- |
| 8 | 0.60 | 0.09 | 0.03 | 0.05 | 0.04 | 0.02 | 0.01 | 0.01 | 0.04 | 0.05 | 0.08 | -- |
| 9 | 0.58 | 0.05 | 0.40 | 0.36 | 0.33 | 0.28 | 0.25 | 0.25 | 0.25 | 0.21 | 0.05 | -- |
| 10 | 0.47 | 0.10 | 0.09 | 0.06 | 0.06 | 0.03 | 0.03 | 0.03 | 0.22 | 0.03 | 0.06 | -- |
| 11 | 0.51 | 0.12 | 0.25 | 0.23 | 0.21 | 0.20 | 0.20 | 0.20 | 0.17 | 0.14 | 0.05 | -- |
| 12 | 0.51 | 0.11 | 0.04 | 0.02 | 0.03 | 0.03 | 0.02 | 0.04 | 0.29 | 0.04 | 0.04 | -- |
| 13 | 0.49 | 0.14 | 0.03 | 0.09 | 0.11 | 0.10 | 0.07 | 0.08 | 0.08 | 0.05 | 0.03 | -- |
| 14 | 0.49 | 0.08 | 0.06 | 0.07 | 0.05 | 0.02 | 0.01 | 0.01 | 0.02 | 0.04 | 0.04 | -- |
| 15 | 0.47 | 0.20 | 0.02 | 0.05 | 0.05 | 0.07 | 0.08 | 0.06 | 0.05 | 0.02 | 0.03 | -- |
| 16 | 0.40 | 0.07 | 0.06 | 0.03 | 0.02 | 0.02 | 0.03 | 0.03 | 0.01 | 0.03 | 0.04 | -- |
| 17 | 0.38 | 0.07 | 0.09 | 0.04 | 0.02 | 0.01 | 0.02 | 0.03 | 0.05 | 0.05 | 0.04 | -- |
| 18 | 0.47 | 0.09 | 0.04 | 0.02 | 0.03 | 0.02 | 0.02 | 0.03 | 0.04 | 0.02 | 0.02 | -- |
| 19 | 0.44 | 0.20 | 0.07 | 0.03 | 0.02 | 0.03 | 0.03 | 0.04 | 0.04 | 0.05 | 0.03 | -- |
| 20 | 0.42 | 0.09 | 0.07 | 0.03 | 0.01 | 0.02 | 0.02 | 0.01 | 0.03 | 0.02 | 0.02 | -- |
| 21 | 0.38 | 0.05 | 0.05 | 0.07 | 0.05 | 0.04 | 0.03 | 0.03 | 0.06 | 0.05 | 0.02 | -- |
| 22 | 0.40 | 0.03 | 0.08 | 0.04 | 0.02 | 0.03 | 0.03 | 0.03 | 0.04 | 0.05 | 0.01 | -- |
| 23 | 0.38 | 0.16 | 0.08 | 0.06 | 0.04 | 0.04 | 0.05 | 0.07 | 0.09 | 0.08 | 0.03 | -- |
| 24 | 0.36 | 0.08 | 0.02 | 0.04 | 0.02 | 0.01 | 0.01 | 0.01 | 0.03 | 0.03 | 0.02 | -- |
| 25 | 0.36 | 0.13 | 0.05 | 0.06 | 0.07 | 0.07 | 0.08 | 0.09 | 0.11 | 0.11 | 0.02 | -- |
| 26 | 0.33 | 0.12 | 0.04 | 0.07 | 0.04 | 0.04 | 0.05 | 0.04 | 0.02 | 0.03 | 0.01 | -- |
| 27 | 0.29 | 0.21 | 0.08 | 0.07 | 0.06 | 0.07 | 0.08 | 0.10 | 0.11 | 0.10 | 0.02 | -- |
| 28 | 0.31 | 0.11 | 0.03 | 0.03 | 0.03 | 0.02 | 0.01 | 0.02 | 0.01 | 0.02 | 0.02 | -- |
| 29 | 0.29 | 0.17 | 0.09 | 0.08 | 0.09 | 0.08 | 0.09 | 0.11 | 0.10 | 0.07 | 0.02 | -- |
| 30 | 0.33 | 0.04 | 0.01 | 0.04 | 0.05 | 0.04 | 0.04 | 0.03 | 0.01 | 0.01 | 0.01 | -- |
| 31 | 0.31 | 0.22 | 0.13 | 0.09 | 0.07 | 0.08 | 0.09 | 0.09 | 0.10 | 0.07 | 0.02 | -- |
| 32 | 0.29 | 0.02 | 0.02 | 0.03 | 0.03 | 0.02 | 0.02 | 0.02 | 0.01 | 0.02 | 0.02 | -- |
| 33 | 0.27 | 0.20 | 0.11 | 0.07 | 0.06 | 0.06 | 0.07 | 0.09 | 0.07 | 0.06 | 0.02 | -- |
| 34 | 0.29 | 0.12 | 0.04 | 0.01 | 0.04 | 0.03 | 0.03 | 0.03 | 0.02 | 0.01 | 0.02 | -- |
| 35 | 0.18 | 0.18 | 0.11 | 0.05 | 0.03 | 0.03 | 0.03 | 0.05 | 0.04 | 0.05 | 0.02 | -- |
| 36 | 0.18 | 0.06 | 0.03 | 0.04 | 0.02 | 0.01 | 0.01 | 0.02 | 0.02 | 0.02 | 0.02 | -- |
| 37 | 0.24 | 0.18 | 0.10 | 0.03 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 | 0.02 | 0.02 | -- |
| 38 | 0.20 | 0.04 | 0.03 | 0.02 | 0.02 | 0.02 | 0.01 | 0.01 | 0.03 | 0.04 | 0.01 | -- |
| 39 | 0.22 | 0.14 | 0.08 | 0.03 | 0.03 | 0.02 | 0.03 | 0.02 | 0.02 | 0.01 | 0.02 | -- |
| 40 | 0.18 | 0.07 | 0.04 | 0.04 | 0.04 | 0.03 | 0.01 | 0.00 | 0.02 | 0.02 | 0.01 | -- |

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

| (5.2.4) | TABLE: Harmonic current limit test (EN 61000-3-2) | | | | | | P |
|----------|---|--------|---------------|--------|---------------|--------|-----------|
| Model | | | | | | | |
| Harmonic | L1 | | -- | | -- | | Limits -A |
| | Magnitude (A) | % of I | Magnitude (A) | % of I | Magnitude (A) | % of I | |
| 02 | 0.17 | -- | -- | -- | -- | -- | 1.08 |
| 03 | 0.09 | -- | -- | -- | -- | -- | 2.30 |
| 04 | 0.08 | -- | -- | -- | -- | -- | 0.43 |
| 05 | 0.15 | -- | -- | -- | -- | -- | 1.14 |
| 06 | 0.02 | -- | -- | -- | -- | -- | 0.30 |
| 07 | 0.05 | -- | -- | -- | -- | -- | 0.77 |
| 08 | 0.02 | -- | -- | -- | -- | -- | 0.23 |
| 09 | 0.01 | -- | -- | -- | -- | -- | 0.40 |
| 10 | 0.01 | -- | -- | -- | -- | -- | 0.18 |
| 11 | 0.01 | -- | -- | -- | -- | -- | 0.33 |
| 12 | 0.01 | -- | -- | -- | -- | -- | 0.15 |
| 13 | 0.01 | -- | -- | -- | -- | -- | 0.21 |
| 14 | 0.01 | -- | -- | -- | -- | -- | 0.13 |
| 15 | 0.01 | -- | -- | -- | -- | -- | 0.15 |
| 16 | 0.01 | -- | -- | -- | -- | -- | 0.12 |
| 17 | 0.01 | -- | -- | -- | -- | -- | 0.13 |
| 18 | 0.00 | -- | -- | -- | -- | -- | 0.10 |
| 19 | 0.00 | -- | -- | -- | -- | -- | 0.12 |
| 20 | 0.00 | -- | -- | -- | -- | -- | 0.09 |
| 21 | 0.01 | -- | -- | -- | -- | -- | 0.11 |
| 22 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 23 | 0.01 | -- | -- | -- | -- | -- | 0.10 |
| 24 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 25 | 0.00 | -- | -- | -- | -- | -- | 0.09 |
| 26 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 27 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 28 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 29 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 30 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 31 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 32 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 33 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 34 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| 35 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 36 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| 37 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 38 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| 39 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 40 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| THD | -- | 4.97 | -- | -- | -- | -- | -- |


This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Annex E.7 Requirements to the Test Report on the NS protection

| | | | |
|--|--|----------------------------------|------------------------------|
| Extract from the test report for the NS protection "Determination of electric properties" | | 2401B1675SHA-001 | |
| Test report NS Protection | | | |
| Type of NS protection: | Integrated NS protection | Further manufacturer indications | |
| Software version: | KS-01 | | |
| Manufacturer: | Shenzhen Kingsource Technology Co., Ltd. | | |
| Measurement period: | 2023-09-04 to 2023-12-30 | | |
| | | Inverter(s) | |
| Protective function | Set value | Tripping value | Tripping value NS protection |
| Rise-in-voltage protection U >> | 1.25 * U _n | 1.252 U _n | 291ms |
| Rise-in-voltage protection U > | 1.10 * U _n | 1.100 U _n | 536 s |
| Voltage drop protection U < | 0.8 * U _n | 0.800 U _n | 186ms |
| Voltage drop protection U < | 0.45 * U _n | 0.448 U _n | 373 ms |
| Frequency decrease protection f < | 47.5Hz | 47.50 Hz | 47 ms |
| Frequency increase protection f > | 51.5Hz | 51.50 Hz | 51 ms |
| <p>^a The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch. When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above. The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms * Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p> | | | |
| <input checked="" type="checkbox"/> For integrated NS protection | | | |
| Assigned to power generation unit of type | | ES-800 | |
| Type integrated interface switch | | (Hongfa) HF115F | |
| Response time of interface switch for integrated NS protection | | 20ms | |
| Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection. | | | |
| NOTE1: U _n =230V | | | |

Remark:

The sample<s> covered in this VOC are incomplete in functional features or limited in performance capabilities and are intended for use and evaluation in other products. See test report for detail information.





Signature

Name: Max Jin

Position: General Manager

Date: 2024-03-06

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

| TEST REPORT VDE-AR-N 4105 Power generation systems connected to the low-voltage distribution network | |
|---|---|
| Report Reference No.: | 2401B1675SHA -001 |
| Tested by (name + signature): | Butch Zang  |
| Approved by (name + signature): | Kevin Zhu  |
| Date of issue : | 2024-03-06 |
| Contents: | 26 pages |
| Testing Laboratory: | Intertek Testing Services Shanghai. |
| Address: | Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China. |
| Testing location / procedure: | TL <input checked="" type="checkbox"/> SMT <input type="checkbox"/> TMP <input type="checkbox"/> |
| Testing location / address: | Same as above |
| Applicant's name : | Shenzhen Lvyou Energy Technology Co., Ltd |
| Address: | 103-104, Building 12, Dawangshan 2nd Industrial Zone, Shajing, Baoan District, Shenzhen, Guangdong, China |
| Test specification: | |
| Standard : | VDE-AR-N 4105:2018 conjunction with DIN VDE V 0124-100:2020 |
| Test procedure: | Type Test |
| Non-standard test method: | N/A |
| Test Report Form/blank test report | |
| Test Report Form No. : | VDE_4105_TTRF_V1.0 |
| TRF Originator : | Intertek Shanghai |
| Master TRF : | 2020-06 |
| This publication may be reproduced in whole or in part for non-commercial purpose as long as Intertek is acknowledged as copyright owner and source of the material. Intertek takes no responsibility and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. | |

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

| | |
|------------------------|--------------------------------|
| Test item description: | Micro Grid-tied Inverter |
| Trade Mark: | N/A |
| Manufacturer: | Same as applicant |
| Model/Type reference: | ES-800 |
| Rating: | See below Specifications table |


| Specifications table | |
|-------------------------------|---|
| Model | ES-800 |
| Input: | |
| Vmax PV (Vdc) | 55 |
| Isc PV (absolute Max.) (A) | 24 |
| Number MPPT trackers | 2 |
| Number input strings | 2 |
| Max. PV input current(A) | 14*2 |
| MPPT voltage range (Vdc) | 16 to 55 |
| Output | |
| Normal Voltage(V) | <input checked="" type="checkbox"/> 1/N/PE 230Vac <input type="checkbox"/> 3 ϕ /N/PE 230/400Vac |
| Frequency (Hz) | <input checked="" type="checkbox"/> 50 Hz <input type="checkbox"/> 60Hz |
| Current (Max. continuous) (A) | 3.13 |
| Power rating (W) | 720 |
| Power Rating (VA) | 720 |
| Power factor /rated | ≥ 0.99 |
| others | |
| Protective class | Class I |
| Ingress protection (IP) | IP 67 |
| Temperature (°C) | -40°C to +65°C |
| Inverter Isolation | <input type="checkbox"/> Non-isolated <input checked="" type="checkbox"/> High frequency isolated |
| Overtoltage category | OVC III (AC Main), OVC II (PV) |
| Weight (kg) | 1.8 |
| Dimensions (WxHxD) (cm) | 22.3 x 4.3 x 23 |

| | |
|---|--|
| Test item particulars | |
| PGU connect to Grid System | <input checked="" type="checkbox"/> 1/N/PE <input type="checkbox"/> 3/PE <input type="checkbox"/> 3/N/PE |
| PGS(kVA) | <input checked="" type="checkbox"/> ≤3.68 <input type="checkbox"/> ≤13.8 <input type="checkbox"/> >13.8 |
| Default cos φ- reactive power adjusted | <input checked="" type="checkbox"/> a fixed displacement factor, cos φ=1 <input type="checkbox"/> Standard characteristic curve for cos φ (P) <input type="checkbox"/> non-Standard characteristic curve for cos φ (P) |
| Function of cos φ/Q- reactive power adjusted | <input checked="" type="checkbox"/> Not adjusted <input type="checkbox"/> a fixed displacement factor cos φ. <input type="checkbox"/> Characteristic curve for cos φ (P) <input type="checkbox"/> Characteristic curve for Q(U) <input type="checkbox"/> Dynamic network supporting (FVRT) |
| Function of active power adjusted | <input checked="" type="checkbox"/> Active power reduction <input type="checkbox"/> Active power output by over-frequency <input type="checkbox"/> Active power output by under-frequency <input type="checkbox"/> P _{AV,E} monitoring |
| NS protection | <input type="checkbox"/> Central NS protection <input checked="" type="checkbox"/> Integrated NS protection |
| Voltage –Line to line | <input type="checkbox"/> Arithmetically from the three line-to-neutral voltages <input checked="" type="checkbox"/> Measured separately. <input checked="" type="checkbox"/> N/A |
| IP protection class : | IP65 |
| Remark PGS: Power Generation System, PGU: Power Generation unit. | |
| Possible test case verdicts: | |
| - test case does not apply to the test object: | N/A |
| - test object does meet the requirement: | P(Pass) |
| - test object does not meet the requirement: | F(Fail) |
| Testing: | |
| Date of receipt of test item : | 2023-09-26 |
| Date (s) of performance of tests : | 2023-09-27 to 2023-12-28 |
| General remarks: | |
| <p>The test results presented in this report relate only to the object (single PV inverter unit) tested. The testing voltage is 230Vac single phase. The information about Generating Plant is not considered and tested.</p> <p>Installer and relevant persons shall comply with VDE-AR-N4105 and relevant standard and Grid Code in this standard.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.</p> <p>"(see Enclosure #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a point is used as the decimal separator.</p> <p>Determination of the test result includes consideration of measurement uncertainty from the test equipment and methods.</p> <p>Determination of the test conclusion is based on IEC Guide 115 in consideration of measurement uncertainty.</p> <p>The test results presented in this report relate only to the item tested. See general product information next for details information.</p> <p>The test does not include the faults inside the CPU and software evaluation as agreed with client. All the tests are performed on a single unit.</p> <p>The clause number in first is about VDE-AR-N 4105 The clause number in bracket is about DIN V VDE V 0124-100</p> | |

General product information:

1. The Hybrid inverter is isolated (transformer) inverter which works convert PV to the grid and load, it intends to be connected into household generation systems and utilizes solar power, utility power and battery power to ensure continuous power supply.
2. In order to protect the inverter, user and installer, external DC and AC circuit breaker shall be equipped for all source port (battery, AC grid) at the end-use application.
3. If certain functions are not permitted by local regulation, the function shall be disabled by hardware or software setting (if applicable) by the manufacturer before putting into the market. For example, it's not permissible to draw electricity from the grid and then feed it back in order to claim statutory reimbursement in some nations.
4. Low voltage electrical installations shall comply with national and local regulations. Only qualified electricians are allowed to install and maintain the converter.

Block diagram:



Version Number:

Software versioning: KS-01

Hardware version number: 0900302

Abbreviations used in the report:

PGU: Power Generation unit.

PGS: Power Generation System

In: Rated current of power generation unit.

Copy of marking plate:

PV Microinverter

| | |
|-------------------------------------|-------------|
| Model | ES-800 |
| Max. Input Voltage (DC) | 55V |
| PV Operating Voltage (DC) | 18V-55V |
| Max. Continuous Input Current (DC) | 2 x 14A |
| Nominal Output Voltage (AC) | 230V |
| Max. Continuous Output Current (AC) | 3.47A |
| Max. Continuous Output Power | 800W |
| Nominal Output Frequency | 50Hz |
| Peak Efficiency | 92% |
| Type of Enclosure | IP67 |
| Protective Class | Class I |
| Operating Ambient Temp. | -40°C~+65°C |



| VDE-AR-N 4105 | | | |
|---------------|---|--|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 4 | General framework conditions | | -- |
| 4.1 | Provisions and regulations | NA for PGU testing | N/A |
| 4.2 | Application procedure and connection relevant documents | NA for PGU testing | N/A |
| 4.3 | Initial start-up of the power generation system | NA for PGU testing | N/A |
| 5 | Network connection | | -- |
| 5.1 | Principles for determination of the network connection point | NA for PGU testing | N/A |
| 5.2 | Rating of the network equipment | NA for PGU testing | N/A |
| 5.3 | Permissible voltage change | NA for PGU testing | N/A |
| 5.4 | Network interactions | | N/A |
| 5.5 | Connection criteria | | -- |
| 5.5.1 | General | | P |
| | When connecting a power generation system or a storage unit, the technical connection conditions of the network operator shall be observed. | Shall be considered full feed-in that in accordance with VDE-AR-N 4100 in the power system | P |
| 5.5.2 | PAV, E monitoring (feed-in limitation) | The independent equipment shall be installed at end use. | N/A |
| 5.5.3 | Power generation systems ready for connection | | N/A |
| 5.6 | Three-phase inverter systems | No Three-phase inverter system will be combined. | N/A |
| 5.7 | Behaviour of the power generation system at the network | | P |
| 5.7.1 | General | | P |
| | For frequencies between 47,5 Hz and 51,5 Hz, automatic disconnection from the network due to a frequency deviation is not permitted. The actual operating principle and the associated exceptions are detailed in 5.7.4.3. Frequency-dependent active power control is implemented in the open-loop control of the power generation units. | | P |
| 5.7.2 | Steady-state voltage stability/reactive power supply | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.2.1 | General boundary conditions | | N/A |
| 5.7.2.2 | Reactive power supply at ΣSE_{max} | | N/A |
| 5.7.2.2.1 | General | | N/A |
| | It is permissible in certain cases described in 5.7.2.2.2 and 5.7.3 to reduce the active power supply to the benefit of the reactive power supply. This is not considered a reduction of the active power supply in the context of network security management. Power generation systems shall comply with the reactive power supply irrespective of the number of feed-inphases under normal operating conditions in the voltage tolerance band $U_n \pm 10\%$. | | N/A |
| 5.7.2.2.2 | Type 2 systems – inverters only | | N/A |
| 5.7.2.2.3 | Type 2 systems – Asynchronous generators (directly connected to the network and principally not able to control any reactive power) | Inverter only | N/A |
| 5.7.2.2.4 | Type 1 systems and type 2 systems – stirling generators and fuel cells | Inverter only | N/A |

| VDE-AR-N 4105 | | | |
|---------------|--|--|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 5.7.2.3 | Reactive power supply smaller than PEmax | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.2.4 | Methods for reactive power supply | No such function, the independent equipment shall be installed at end use. | N/A |
| | a) reactive power voltage characteristic curve Q(U); or | | N/A |
| | b) displacement factor/active power characteristic curve $\cos \phi$ (P); or | | N/A |
| | c) fixed displacement factor $\cos \phi$. | | N/A |
| | The Q(U) rule applies only to three-phase power generation units connected to the three-phase current system. | | N/A |
| 5.7.2.5 | Requirements for reactive power methods of type 2 systems (inverters only) and type 1 systems | No such function, the independent equipment shall be installed at end use. | N/A |
| | In the delivery state, none of the three reactive power methods specified in 5.7.2.4 is set as default. During the commissioning of power generation units, the method specified by the network operator shall be set by the system installer. Without the setting of the method specified by the network operator, power generation units shall not feed in any power. | | N/A |
| 5.7.2.6 | Special aspects regarding the extension of power generation systems | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.3 | Dynamic network stability | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.3.1 | General | | N/A |
| 5.7.3.2 | Dynamic network stability for type 1 units Transient stability – Reaction to network faults | | N/A |
| 5.7.3.3 | Dynamic network stability for type 2 units and storage units | No such function, the independent equipment shall be installed at end use. | N/A |
| | The following conditions apply to all type 2 power generation units and storage units: As long as the line-neutral-voltages at the generator terminals of the power generation unit or storage unit do not exceed the limit curves shown in Figure 12 (red for the under-voltage limit curve, blue for the over-voltage limit curve), both the power generation unit and the storage unit shall neither become unstable nor disconnect from the network throughout the operating range. | | N/A |

| VDE-AR-N 4105 | | | |
|---------------|---|--|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | For evaluating the curves, the smallest respective value of the line-neutral-voltages at the power generation unit or the storage unit shall be used in case of a voltage drop, and the highest respective value of the line-neutral- voltages at the power generation unit or the storage unit shall be used in case of a voltage rise. As far as the set values for the NS protection given in Table 2 (column "Inverter(s)") anticipate the requirements given in Figure 12 in certain working points, merely the checking of the set values for NS protection is required for the verification procedure. | | N/A |
| | If the voltage at the generator terminals falls below $< 0,8 U_n$ or exceeds $> 1,15 U_n$ (onset of fault), type 2 power generation units and storage units shall ride through voltage drops without feeding current into the network of the network operator (limited dynamic network stability). | | N/A |
| | This requirement is deemed to be met, if the current fed in by the power generation unit(s) and/or the storage unit in any line conductor does not exceed 20 % of the rated current I_r within 60 ms and 10 % of I_r within 100 ms upon a voltage drop below $0,8 U_n$ or a voltage rise above $1,15 U_n$. | | N/A |
| | Behaviour after the end of a fault. If, after the end of a fault, the network voltage resumes a value within the voltage band from $-15 \% U_n$ to $+10 \% U_n$ and the active current of the power generation unit and/or the storage unit has been reduced during the network fault, it shall, immediately after the end of the fault, be increased to its pre-fault value as quickly as possible. The transient period shall not exceed a maximum of 1 s. The reactive power supply follows 5.7.2.5 in its time-related behaviour. In case of rotating machinery, the transient period shall not exceed a maximum of 6 s. At voltages of $1,15 U_n$, the power generation units and storage units shall not disconnect from the network for a period of up to 60 s after the onset of the fault. If the tripping of the self-protection of the power generation units and/or the storage unit is imminent, these units can adjust their reactive power behaviour such as to prevent self-protection tripping. | | N/A |
| 5.7.4 | Active power output | | P |
| 5.7.4.1 | General | | P |
| | In cases where set-points are specified by a third party (e. g. direct marketing) and of network security management in accordance with 5.7.4.2, the new set-point shall be approached with the customer installation's power gradients listed below in relation to the network connection point. Implementation of those power gradients directly at the power generation units or storage units is sufficient for meeting the requirement. | The active power can be remote-controlled on the communication interface | P |
| 5.7.4.2 | Network security management | | P |
| 5.7.4.2.1 | Types of power generation systems and storage units | The active power can be remotely controlled on the communication interface | P |

| VDE-AR-N 4105 | | | |
|---------------|--|--|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | Photovoltaic systems | | P |
| | Cogeneration of power and heat (CHP) systems, wind, biogas, hydroelectric power as well as landfill and sewage gas systems | | N/A |
| | Storage units buffering EEG or KWKG systems | | N/A |
| | Any EEG and KWKG systems with an intelligent measurement system | | N/A |
| | Any power generation systems and storage units other than those indicated above | | N/A |
| 5.7.4.2.2 | Implementation of network security management | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.4.2.3 | Active power adjustment at over-frequency and under-frequency | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.4.4 | Voltage-dependent active power reduction | No such function, the independent equipment shall be installed at end use. | N/A |
| 5.7.5 | <p>Short-circuit contribution</p> <p>Due to the operation of a power generation system, the short-circuit current of the low-voltage network is increased by the short-circuit current of the power generation system. Therefore, the short-circuit current of the power generation system to be expected at the network connection point shall be indicated in accordance with 4.2. For the determination of the initial short-circuit AC current contribution I_{kA} of a power generation system, the following roughly estimated values can be assumed:</p> <ul style="list-style-type: none"> – for synchronous generators: 8 times the rated current; – for asynchronous generators: 6 times the rated current; – for generators and storage units with inverters: the rated current. <p>If the power generation system causes a short-circuit current increase in the network operator's network in excess of the rated value, then connection owner and network operator shall agree upon appropriate measures limiting the short-circuit current from the power generation system accordingly.</p> | | P |
| 6 | Construction of the power generation system/network and system protection (NS protection) | | -- |
| 6.1 | General requirements | | N/A |
| | <p>The network and system protection (NS protection) is a type-tested protective device with a NS protection certificate (see Form E.6) wherein all protective functions specified in 6.5 are installed. The NS protection acts on the interface switch in accordance with 6.4.</p> <p>Depending on the sum of the maximum apparent powers of all power generation systems and storage units connected to the same network connection point ΣS_{Amax}, the following conditions apply to the NS protection:</p> | | P |
| 6.2 | Central NS protection | | N/A |
| 6.3 | Integrated NS protection | integrated NS protection | P |
| 6.4 | Interface switch | | P |
| 6.4.1 | General | | P |

| VDE-AR-N 4105 | | | |
|---------------|--|----------------------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| | For the connection of the power generation system to the network operator's low-voltage network or to the remaining customer installation, an interface switch shall be used. The interface switch is controlled by the NS protection and automatically triggers if at least one protective function responds. | | P |
| | The functional check of the interface switch shall be carried out according to a) or b) or c): a) by using an interface switch which, in its active state, requires a control voltage to be applied continuously and which disconnects automatically when this voltage is no longer applied. The operational connection and disconnection processes shall be monitored; b) by connection and disconnection of the interface switch via the NS protection and monitoring its proper functioning (e. g. break contact of a monitoring contact) at least once daily; c) by using the integrated interface switch and the integrated NS protection for PV and battery inverters in compliance | | P |
| 6.4.2 | Central interface switch | | N/A |
| 6.4.3 | Integrated interface switch | | N/A |
| | In the case of integrated NS protection, the NS protection can be integrated in the programmable system control of the power generation units (e.g. in the inverter control). If so, then both the test button and the sealing may be omitted, however, password protection is required, if the protective function $U >$ is adjustable. The integrated NS protection acts on an integrated interface switch (see 6.4.3). | | N/A |
| 6.5 | Protective devices and protection settings | | P |
| 6.5.1 | General | | P |
| | The purpose of NS protection is to disconnect the power generation system from the network in the event of inadmissible voltage and frequency values (also refer to DIN VDE 0100-551 (VDE 0100-551)). This is meant to prevent inadvertent feed-in from the power generation system into a partial network separated from the main distribution network. | | P |
| 6.5.2 | Protective functions | | P |
| | The NS protection shall be provided with a means for preventing unauthorised access (z. B. sealable, password protection). The rise-in-voltage protection $U >$ shall be designed such as to be adjustable in the NS protection (see Table 2, Footnote b). Additionally, the time delay of the voltage drop protection $U <$ and $U <<$ for directly coupled synchronous and asynchronous generators with $P_n > 50$ kW shall also be designed such as to be adjustable in the NS protection (see Table 2, Footnote d). Any other protective functions listed in 6.5.1 are either to be installed permanently, i. e. not adjustable, in the NS protection or to be provided with an additional separate protection against unauthorised access (e. g. password protection) for preventing modifications. | | P |
| 6.5.3 | Islanding detection | (See appended table) | P |
| 6.6 | Further requirements for power generation systems | Shall be considered in PGS | NA |
| 7 | Metering for billing purposes | | NA |
| 8 | Operation of the system | | P |

| VDE-AR-N 4105 | | | |
|---------------|---|----------------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 8.1 | General | | P |
| 8.2 | Special aspects of the management of the network operator's network | | NA |
| 8.3 | Connection conditions and synchronisation | | P |
| 8.3.1 | General | | P |
| | <p>Power generation systems and storage units shall be connected to the network operator's network only if a suitable device determines that both the mains voltage and the mains frequency are within the tolerance range of 85 % Un to 110 % Un or 47,5 Hz to 50,1 Hz, respectively, for a period of at least 60 seconds.</p> <p>Additionally, the delay times for the reconnection of a generator and the staggered times applicable when connecting several generators shall be sufficient for safely finishing any control and adjustment processes within the power generation system and/or the storage unit caused by the connection.</p> <p>In case of power generation systems and storage units being reconnected to the network operator's network at the tripping of the NS protective device or the PAV, E monitoring, the active power of controllable power generation systems and storage units supplied to the network operator's network shall not exceed the gradient of 10 % of the active power P_{Amax} per minute. Non-controllable power generation systems and storage units can connect after 1 min to 10 min (random generator) or later.</p> | (See appended table) | P |
| 8.3.2 | Connection of synchronous generators | | N/A |
| 8.3.3 | Connection of asynchronous generators | | N/A |
| 8.3.4 | <p>Connection of power generation units and storage units with inverters</p> <p>Power generation units with inverters (such as photovoltaic systems) and storage units with inverters shall only be connected with $k_{max} \leq 1,2$.</p> | | P |
| 8.4 | Special aspects regarding the planning, installation and operation of power generation systems and storage units each with P _{Amax} ≥ 135 kW | | NA |
| 9 | Verification of electrical properties | | P |
| | Annex A: Explanations (informative) | | --- |
| | Annex B: Connection examples and measurement strategies (informative) | | --- |
| | Annex C: Examples of meter panel configurations (informative) | | --- |
| | Annex D: Examples for the connection evaluation of power generation systems -Connection of a 20 kW PV system (informative) | | --- |

| DIN VDE V 0124-100 | | | |
|--------------------|--|-----------------|---------|
| Clause | Requirement - Test | Result - Remark | Verdict |
| 5.2.2 | Rapid voltage change (Kimax) | | P |
| 5.2.3 | Flicker | | P |
| 5.2.4 | Harmonics and Inter-harmonics (I inter, I higher) | | P |
| 5.2.5 | Commutation notches | | N/A |
| 5.2.6 | DC current feeding to network (Idc) | | P |
| 5.3.2 | Tests of three-phase inverter (Imbalance) | | N/A |
| 5.3.3 | Symmetry operation with a symmetry device | | N/A |
| 5.4.2 | Measurement of active- and reactive power ranges (P&Q range) | | N/A |
| 5.4.3 | Active power reduction through setting provision (P control) | | P |
| 5.4.4 | Active power output of PGU by over-frequency (LFSM-O) | | N/A |
| 5.4.5 | Active power output of ESS by over-frequency (LFSM-O) | | N/A |
| 5.4.6 | Active power output of PGU by under-frequency (LFSM-U) | | N/A |
| 5.4.7 | Active power output of ESS by under-frequency (LFSM-U) | | N/A |
| 5.4.8.2 | Tests of reactive power / displacement factor setting accuracy (Fixed $\cos\phi$) | | N/A |
| 5.4.8.3 | Tests of displacement factor- / active power character curve ($\cos\phi$ (P)) | | N/A |
| 5.4.8.4 | Tests of reactive power-voltage character curve (Q(U)) | | N/A |
| 5.5.2 | NS-protection | | N/A |
| 5.5.3 | Central NS-protecton | | N/A |
| 5.5.4 | Integrated NS-protection | | N/A |
| 5.5.6 | Interface switch (Functional safety) | | P |
| 5.5.7 | Protection devices and protection settings (OV/UV, OF/UF) | | P |
| 5.5.9 | Constructional features of NS protection | | P |
| 5.5.10 | Islanding detection | | P |
| 5.6 | Connection conditions and synchronization (Reconnection) | | P |
| 5.7 | Verification of $P_{AV,E}$ monitoring | | N/A |
| 5.8 | Verification of dynamic network supporting (FVRT) | | N/A |

Appendix table1

| 8.3.4 (5.2.2) | TABLE: Rapid voltage change (Kimax) | | | P |
|---------------------|-------------------------------------|------|------|-------|
| Test Conditions | Measurements | | | Limit |
| | U/Un | I/In | Ki | Ki |
| Starting to 50%Pn | 1.00 | 0.36 | 0.12 | ≤ 1.2 |
| Starting to 100% Pn | 1.00 | 3.14 | 1.00 | ≤ 1.2 |
| Stopping at 100% Pn | 1.00 | 3.08 | 0.98 | ≤ 1.2 |
| Note(s): | | | | |

| (5.2.3) | TABLE: Flicker | | | | P |
|---|----------------|-------|---------|----------|---|
| Measurement | Plt | 0.11 | | | |
| | Limit | 0.65 | | | |
| | Pst | dc[%] | dmax[%] | d(t)[ms] | |
| | 1.0 | 3.3 | 4.0 | 500 | |
| 1 | 0.084 | 0.096 | 0.178 | 0.0 | |
| 2 | 0.120 | 0.127 | 0.280 | 0.0 | |
| 3 | 0.129 | 0.187 | 0.260 | 0.0 | |
| 4 | 0.136 | 0.151 | 0.399 | 0.0 | |
| 5 | 0.080 | 0.136 | 0.170 | 0.0 | |
| 6 | 0.080 | 0.111 | 0.172 | 0.0 | |
| 7 | 0.080 | 0.108 | 0.180 | 0.0 | |
| 8 | 0.081 | 0.098 | 0.148 | 0.0 | |
| 9 | 0.082 | 0.109 | 0.164 | 0.0 | |
| 10 | 0.130 | 0.159 | 0.350 | 0.0 | |
| 11 | 0.125 | 0.082 | 0.245 | 0.0 | |
| 12 | 0.129 | 0.104 | 0.222 | 0.0 | |
| Note(s): PGU and ESS with nominal current ≤75A (Per DIN EN 61000-3-3) | | | | | |

| (5.2.4) | | TABLE: Harmonics | | | | | | | | | | P |
|----------------------|----------|------------------|------|------|------|------|------|------|------|------|------|-------|
| Harmonics | | | | | | | | | | | | |
| P/P _n [%] | 0 | 10 | 20 | 30 | 40 | 50 | 60 | 70 | 80 | 90 | 100 | Limit |
| Order No. | I/In [%] | | | | | | | | | | | |
| 2 | 0.73 | 0.37 | 0.35 | 0.34 | 0.36 | 0.37 | 0.38 | 0.34 | 0.41 | 0.44 | 0.56 | -- |
| 3 | 0.58 | 0.98 | 0.36 | 0.29 | 0.23 | 0.21 | 0.17 | 0.22 | 0.19 | 0.21 | 0.30 | -- |
| 4 | 0.47 | 0.21 | 0.19 | 0.21 | 0.16 | 0.15 | 0.16 | 0.13 | 0.12 | 0.17 | 0.27 | -- |
| 5 | 0.56 | 1.16 | 0.69 | 0.59 | 0.53 | 0.51 | 0.44 | 0.34 | 0.32 | 0.39 | 0.50 | -- |
| 6 | 0.56 | 0.18 | 0.03 | 0.05 | 0.07 | 0.07 | 0.08 | 0.09 | 0.09 | 0.03 | 0.07 | -- |
| 7 | 0.53 | 0.74 | 0.56 | 0.44 | 0.39 | 0.38 | 0.42 | 0.40 | 0.36 | 0.28 | 0.18 | -- |
| 8 | 0.60 | 0.09 | 0.03 | 0.05 | 0.04 | 0.02 | 0.01 | 0.01 | 0.04 | 0.05 | 0.08 | -- |
| 9 | 0.58 | 0.05 | 0.40 | 0.36 | 0.33 | 0.28 | 0.25 | 0.25 | 0.25 | 0.21 | 0.05 | -- |
| 10 | 0.47 | 0.10 | 0.09 | 0.06 | 0.06 | 0.03 | 0.03 | 0.03 | 0.22 | 0.03 | 0.06 | -- |
| 11 | 0.51 | 0.12 | 0.25 | 0.23 | 0.21 | 0.20 | 0.20 | 0.20 | 0.17 | 0.14 | 0.05 | -- |
| 12 | 0.51 | 0.11 | 0.04 | 0.02 | 0.03 | 0.03 | 0.02 | 0.04 | 0.29 | 0.04 | 0.04 | -- |
| 13 | 0.49 | 0.14 | 0.03 | 0.09 | 0.11 | 0.10 | 0.07 | 0.08 | 0.08 | 0.05 | 0.03 | -- |
| 14 | 0.49 | 0.08 | 0.06 | 0.07 | 0.05 | 0.02 | 0.01 | 0.01 | 0.02 | 0.04 | 0.04 | -- |
| 15 | 0.47 | 0.20 | 0.02 | 0.05 | 0.05 | 0.07 | 0.08 | 0.06 | 0.05 | 0.02 | 0.03 | -- |
| 16 | 0.40 | 0.07 | 0.06 | 0.03 | 0.02 | 0.02 | 0.03 | 0.03 | 0.01 | 0.03 | 0.04 | -- |
| 17 | 0.38 | 0.07 | 0.09 | 0.04 | 0.02 | 0.01 | 0.02 | 0.03 | 0.05 | 0.05 | 0.04 | -- |
| 18 | 0.47 | 0.09 | 0.04 | 0.02 | 0.03 | 0.02 | 0.02 | 0.03 | 0.04 | 0.02 | 0.02 | -- |
| 19 | 0.44 | 0.20 | 0.07 | 0.03 | 0.02 | 0.03 | 0.03 | 0.04 | 0.04 | 0.05 | 0.03 | -- |
| 20 | 0.42 | 0.09 | 0.07 | 0.03 | 0.01 | 0.02 | 0.02 | 0.01 | 0.03 | 0.02 | 0.02 | -- |
| 21 | 0.38 | 0.05 | 0.05 | 0.07 | 0.05 | 0.04 | 0.03 | 0.03 | 0.06 | 0.05 | 0.02 | -- |
| 22 | 0.40 | 0.03 | 0.08 | 0.04 | 0.02 | 0.03 | 0.03 | 0.03 | 0.04 | 0.05 | 0.01 | -- |
| 23 | 0.38 | 0.16 | 0.08 | 0.06 | 0.04 | 0.04 | 0.05 | 0.07 | 0.09 | 0.08 | 0.03 | -- |
| 24 | 0.36 | 0.08 | 0.02 | 0.04 | 0.02 | 0.01 | 0.01 | 0.01 | 0.03 | 0.03 | 0.02 | -- |
| 25 | 0.36 | 0.13 | 0.05 | 0.06 | 0.07 | 0.07 | 0.08 | 0.09 | 0.11 | 0.11 | 0.02 | -- |
| 26 | 0.33 | 0.12 | 0.04 | 0.07 | 0.04 | 0.04 | 0.05 | 0.04 | 0.02 | 0.03 | 0.01 | -- |
| 27 | 0.29 | 0.21 | 0.08 | 0.07 | 0.06 | 0.07 | 0.08 | 0.10 | 0.11 | 0.10 | 0.02 | -- |
| 28 | 0.31 | 0.11 | 0.03 | 0.03 | 0.03 | 0.02 | 0.01 | 0.02 | 0.01 | 0.02 | 0.02 | -- |
| 29 | 0.29 | 0.17 | 0.09 | 0.08 | 0.09 | 0.08 | 0.09 | 0.11 | 0.10 | 0.07 | 0.02 | -- |
| 30 | 0.33 | 0.04 | 0.01 | 0.04 | 0.05 | 0.04 | 0.04 | 0.03 | 0.01 | 0.01 | 0.01 | -- |
| 31 | 0.31 | 0.22 | 0.13 | 0.09 | 0.07 | 0.08 | 0.09 | 0.09 | 0.10 | 0.07 | 0.02 | -- |
| 32 | 0.29 | 0.02 | 0.02 | 0.03 | 0.03 | 0.02 | 0.02 | 0.02 | 0.01 | 0.02 | 0.02 | -- |
| 33 | 0.27 | 0.20 | 0.11 | 0.07 | 0.06 | 0.06 | 0.07 | 0.09 | 0.07 | 0.06 | 0.02 | -- |
| 34 | 0.29 | 0.12 | 0.04 | 0.01 | 0.04 | 0.03 | 0.03 | 0.03 | 0.02 | 0.01 | 0.02 | -- |
| 35 | 0.18 | 0.18 | 0.11 | 0.05 | 0.03 | 0.03 | 0.03 | 0.05 | 0.04 | 0.05 | 0.02 | -- |
| 36 | 0.18 | 0.06 | 0.03 | 0.04 | 0.02 | 0.01 | 0.01 | 0.02 | 0.02 | 0.02 | 0.02 | -- |
| 37 | 0.24 | 0.18 | 0.10 | 0.03 | 0.01 | 0.01 | 0.01 | 0.01 | 0.02 | 0.02 | 0.02 | -- |
| 38 | 0.20 | 0.04 | 0.03 | 0.02 | 0.02 | 0.02 | 0.01 | 0.01 | 0.03 | 0.04 | 0.01 | -- |
| 39 | 0.22 | 0.14 | 0.08 | 0.03 | 0.03 | 0.02 | 0.03 | 0.02 | 0.02 | 0.01 | 0.02 | -- |
| 40 | 0.18 | 0.07 | 0.04 | 0.04 | 0.04 | 0.03 | 0.01 | 0.00 | 0.02 | 0.02 | 0.01 | -- |

| (5.2.4) | TABLE: Harmonic current limit test (EN 61000-3-2) | | | | | | P |
|----------|---|--------|---------------|--------|---------------|--------|-----------|
| Model | NBQ800 | | | | | | |
| Harmonic | L1 | | -- | | -- | | Limits -A |
| | Magnitude (A) | % of I | Magnitude (A) | % of I | Magnitude (A) | % of I | |
| 02 | 0.17 | -- | -- | -- | -- | -- | 1.08 |
| 03 | 0.09 | -- | -- | -- | -- | -- | 2.30 |
| 04 | 0.08 | -- | -- | -- | -- | -- | 0.43 |
| 05 | 0.15 | -- | -- | -- | -- | -- | 1.14 |
| 06 | 0.02 | -- | -- | -- | -- | -- | 0.30 |
| 07 | 0.05 | -- | -- | -- | -- | -- | 0.77 |
| 08 | 0.02 | -- | -- | -- | -- | -- | 0.23 |
| 09 | 0.01 | -- | -- | -- | -- | -- | 0.40 |
| 10 | 0.01 | -- | -- | -- | -- | -- | 0.18 |
| 11 | 0.01 | -- | -- | -- | -- | -- | 0.33 |
| 12 | 0.01 | -- | -- | -- | -- | -- | 0.15 |
| 13 | 0.01 | -- | -- | -- | -- | -- | 0.21 |
| 14 | 0.01 | -- | -- | -- | -- | -- | 0.13 |
| 15 | 0.01 | -- | -- | -- | -- | -- | 0.15 |
| 16 | 0.01 | -- | -- | -- | -- | -- | 0.12 |
| 17 | 0.01 | -- | -- | -- | -- | -- | 0.13 |
| 18 | 0.00 | -- | -- | -- | -- | -- | 0.10 |
| 19 | 0.00 | -- | -- | -- | -- | -- | 0.12 |
| 20 | 0.00 | -- | -- | -- | -- | -- | 0.09 |
| 21 | 0.01 | -- | -- | -- | -- | -- | 0.11 |
| 22 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 23 | 0.01 | -- | -- | -- | -- | -- | 0.10 |
| 24 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 25 | 0.00 | -- | -- | -- | -- | -- | 0.09 |
| 26 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 27 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 28 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 29 | 0.00 | -- | -- | -- | -- | -- | 0.08 |
| 30 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 31 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 32 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 33 | 0.00 | -- | -- | -- | -- | -- | 0.07 |
| 34 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| 35 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 36 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| 37 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 38 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| 39 | 0.00 | -- | -- | -- | -- | -- | 0.06 |
| 40 | 0.00 | -- | -- | -- | -- | -- | 0.05 |
| THD | -- | 3.25 | -- | -- | -- | -- | -- |

| (5.2.6) | TABLE: Direct current injection | | | | | | P |
|----------------|---------------------------------|--------|--------|--------|--------|--------|-----------|
| Power P/Pn [%] | Measured DC output current | | | | | | Limit [%] |
| | L1 [A] | L1 [%] | L2 [A] | L2 [%] | L3 [A] | L3 [%] | |
| 95% | 0.017 | 0.48 | -- | -- | -- | -- | 0.5% |
| 66% | 0.016 | 0.46 | -- | -- | -- | -- | 0.5% |
| 33% | 0.016 | 0.46 | -- | -- | -- | -- | 0.5% |

Supplementary information: Main voltage 230V

| | | | |
|-------------------------|---|----------------------------|--------------------|
| 5.4.3 | TABLE: Active power reduction through setting provision (P control) | | P |
| Test Conditions | Measurements | | Limit |
| P/Pn [%] | P/P _{E_{max}} [%] | $\Delta P/P_{E_{max}}$ [%] | $\Delta P/P_n$ [%] |
| 100 | 98.88 | 1.12 | ≤ 5% |
| 90 | 85.91 | 4.09 | |
| 80 | 76.54 | 3.46 | |
| 70 | 67.10 | 3.90 | |
| 60 | 58.16 | 1.84 | |
| 50 | 48.98 | 1.02 | |
| 40 | 39.52 | 0.48 | |
| 30 | 29.93 | 0.07 | |
| 20 | 20.13 | 0.13 | |
| 10 | 10.15 | 0.15 | |
| No disconnection occurs | | | |

| | | | |
|-----------------|---|--|-----------------------------|
| 5.4.3 | TABLE: Active power reduction through setting provision (P control) | | P |
| Test Conditions | Measurements | | Limit |
| P/Pn [%] | $\Delta P/\Delta t$ [%Pn/s] | | $\Delta P/\Delta t$ [%Pn/s] |
| 100->5 | 0.54 | | 0.33-0.66 |
| 5->100 | 0.56 | | |

| | | | |
|-----------------|---|---------------------------|---|
| 5.4.3 | TABLE: Active power reduction through setting provision (P control) | | P |
| Test Conditions | Measurements | Limit | |
| P/Pn [%] | T _{response} [s] | T _{response} [s] | |
| 100->0 | 1.5 | ≤ 5 | |
| Note(s): | | | |

| 5.5.2, 5.5.3, 5.5.4 | TABLE: Interface switch (Functional safety) | | N/A | | | | |
|--|---|-------|------------------|-----------|----------|------------------|--------|
| <input checked="" type="checkbox"/> Integrated interface switch | | | | | | | |
| <input checked="" type="checkbox"/> Complied with DIN EN 62109-2 | | | | | | | |
| Switch manufacturer and type: Xiamen Hongfa Electroacoustics Co., Ltd; HF115F | | | | | | | |
| Response time of interface switch for integrated NS protection: 20ms | | | | | | | |
| The max. initial short-circuited current of PGU I _k "': 1.52A | | | | | | | |
| No. | component No. | fault | test voltage (V) | test time | fuse No. | fuse current (A) | result |
| 1. | | | | | | | |
| Supplement: s-c: short-circuited, o-c: open-circuited, o-l: overload | | | | | | | |

| 6.5.2(5.5.7) | | TABLE: Protection devices and protection settings (OV/UV) | | | | P |
|---|---------------------|---|---------------|-------|-------|---------------------------------|
| Condition | Setting U/Un [%] | Measurement | | | | Limitation $\Delta U/Un$ [%] |
| | | Trip value [V] | | | | |
| | | L123 | L1 | L2 | L3 | |
| U>> | 125 | -- | 291.43 | -- | -- | $\leq \pm 1.0$ |
| U< | 80 | -- | 186.68 | -- | -- | |
| U<< | 45 | -- | 108.25 | -- | -- | |
| Condition | Setting U/Un [%] | Measurement | | | | Limitation $\Delta U/Un$ [%] |
| | | Trip value [V] | | | | |
| | | L123 | L1-L2 | L2-L3 | L3-L1 | |
| U>> | 125 | -- | -- | -- | -- | $\leq \pm 1.0$ |
| U< | 80 | -- | -- | -- | -- | |
| U<< | 45 | -- | -- | -- | -- | |
| Condition | Setting [ms] | Measurement | | | | Limitation [ms] |
| | | Trip time [ms] | | | | |
| | | L123 | L1 | L2 | L3 | |
| U>> | 100 | -- | 133 | -- | -- | ≤ 200 |
| U< | 3000 | -- | 3020 | -- | -- | 3000-3100 |
| U<< | 300 | -- | 373 | -- | -- | 300-400 |
| Condition | Setting | Measurement | | | | Limitation [ms] |
| | | Trip time [ms] | | | | |
| | | L123 | L1-L2 | L2-L3 | L3-L1 | |
| U>> | 100 | -- | -- | -- | -- | ≤ 200 |
| U< | 3000 | -- | -- | -- | -- | 3000-3100 |
| U<< | 300 | -- | -- | -- | -- | 300-400 |
| Condition | Setting [s] | Measurement | | | | Limitation [s] |
| | | Trip time [s] | | | | |
| | | L123 | L1 | L2 | L3 | |
| U> 230->257.6 | 500 | -- | 536 | -- | -- | 450-550 |
| U> 230->248.4 | No disconnect | -- | No disconnect | -- | -- | No disconnect |
| U> 244->262.2 | 300 | -- | 322 | -- | -- | 225-375 |
| Note(s): Tests on L-L voltages are applicable to product over 30kVA. | | | | | | |

| 6.5.2(5.5.7) TABLE: Protection devices and protection settings (OF/UF) | | | P |
|--|-------------------|-----------------|----------------------------------|
| Condition | Setting f [Hz] | Measurement | Limitation $\Delta f/f_n$ [%] |
| | | Trip value [Hz] | |
| f> | 51.5 | 51.5 | ≤±0.5 |
| f< | 47.5 | 47.6 | |
| Condition | Setting [ms] | Measurement | Limitation [ms] |
| | | Trip time [ms] | |
| f> | 100 | 193.5 | ≤200 |
| f< | 100 | 170.0 | ≤200 |
| Note(s): | | | |

| 6.5.3 (5.5.10) TABLE: Islanding detection (per IEC 62116: 2014) | | | | | | P |
|---|--------------------|----------------------|----------------------|----------------|----------------|-----------------|
| Power 100% | | | | | | |
| Conditions | P _R [W] | Q _L [Var] | Q _C [Var] | Q _f | Trip time [ms] | Limitation [ms] |
| P _R : -10% Q _C : +10% | L1: 658 | L1: 871 | L1: 769 | 1.244 | 960 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -10% Q _C : +5% | L1: 653 | L1: 831 | L1: 769 | 0.224 | 820 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -10% Q _C : 0% | L1: 652 | L1: 793 | L1: 769 | 1.198 | 1894 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -10% Q _C : -5% | L1: 648 | L1: 753 | L1: 769 | 1.174 | 502 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -10% Q _C : -10% | L1: 646 | L1: 714 | L1: 769 | 1.1476 | 968 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -5% Q _C : +10% | L1: 692 | L1: 871 | L1: 769 | 1.183 | 500 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -5% Q _C : -10% | L1: 676 | L1: 714 | L1: 766 | 1.0940 | 833 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _C : +10% | L1: 725 | L1: 871 | L1: 769 | 1.129 | 1083 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -5% Q _C : +5% | L1: 685 | L1: 831 | L1: 766 | 1.164 | 585 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -5% Q _C : 0% | L1: 683 | L1: 793 | L1: 766 | 1.139 | 1209 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : -5% Q _C : -5% | L1: 680 | L1: 753 | L1: 766 | 1.117 | 1737 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |



| | | | | | | |
|----------------------|---------|----------|----------|--------|----------------|-----------------|
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: 0% QC: +5% | L1: 720 | L1: 831 | L1: 769 | 1.111 | 1782 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: 0% QC: 0% | L1: 719 | L1: 793 | L1: 769 | 1.086 | 800 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: 0% QC: -5% | L1: 714 | L1: 753 | L1: 769 | 1.0663 | 1703 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +5% QC: +5% | L1: 754 | L1: 831 | L1: 769 | 1.0598 | 619 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +5% QC: 0% | L1: 753 | L1: 793 | L1: 769 | 1.037 | 729 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +5% QC: -5% | L1: 749 | L1: 753 | L1: 769 | 1.016 | 737 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: 0% QC: -10% | L1: 710 | L1: 714 | L1: 769 | 1.043 | 671 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +5% QC: +10% | L1: 758 | L1: 871 | L1: 769 | 1.078 | 774 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +5% QC: -10% | L1: 745 | L1: 714 | L1: 769 | 0.994 | 1097 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +10% QC: +10% | L1: 788 | L1: 868 | L1: 766 | 1.034 | 160 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +10% QC: +5% | L1: 782 | L1: 828 | L1: 765 | 1.017 | 417 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +10% QC: 0% | L1: 782 | L1: 791 | L1: 766 | 0.995 | 281 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +10% QC: -5% | L1: 781 | L1: 753 | L1: 769 | 0.9745 | 1126 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| PR: +10% QC: -10% | L1: 779 | L1: 714 | L1: 769 | 0.951 | 331 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Power 66% | | | | | | |
| Conditions | Pr [W] | Ql [Var] | Qc [Var] | Qf | Trip time [ms] | Limitation [ms] |
| PR: 0% | L1: 471 | L1: 476 | L1: 461 | 0.995 | 635 | |

| Qc: -5% | L2: -- | L2: -- | L2: -- | -- | | 9000 |
|-------------------|---------|----------|----------|-------|----------------|-----------------|
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -4% | L1: 472 | L1: 482 | L1: 461 | 0.998 | 360 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -3% | L1: 473 | L1: 486 | L1: 461 | 1.001 | 990 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -2% | L1: 473 | L1: 492 | L1: 461 | 1.007 | 523 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -1% | L1: 474 | L1: 497 | L1: 461 | 1.009 | 292 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: 0% | L1: 475 | L1: 502 | L1: 461 | 1.013 | 887 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: +1% | L1: 475 | L1: 507 | L1: 461 | 1.017 | 778 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: +2% | L1: 476 | L1: 512 | L1: 461 | 1.020 | 283 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: +3% | L1: 474 | L1: 515 | L1: 461 | 1.029 | 572 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: +4% | L1: 474 | L1: 520 | L1: 461 | 1.032 | 433 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: +5% | L1: 475 | L1: 525 | L1: 461 | 1.037 | 822 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Power 33% | | | | | | |
| Conditions | Pr [W] | Ql [Var] | Qc [Var] | Qf | Trip time [ms] | Limitation [ms] |
| Pr: 0% Qc: -5% | L1: 238 | L1: 278 | L1: 213 | 1.022 | 632 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -4% | L1: 239 | L1: 282 | L1: 213 | 1.027 | 761 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -3% | L1: 239 | L1: 284 | L1: 213 | 1.031 | 511 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| Pr: 0% Qc: -2% | L1: 239 | L1: 288 | L1: 213 | 1.036 | 588 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |


| | | | | | | |
|---|---------|---------|---------|-------|-----|------|
| P _R : 0% Q _c : -1% | L1: 239 | L1: 291 | L1: 213 | 1.044 | 651 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _c : 0% | L1: 239 | L1: 294 | L1: 213 | 1.046 | 976 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _c : +1% | L1: 240 | L1: 297 | L1: 213 | 1.048 | 583 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _c : +2% | L1: 241 | L1: 300 | L1: 213 | 1.049 | 720 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _c : +3% | L1: 234 | L1: 303 | L1: 213 | 1.085 | 401 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _c : +4% | L1: 234 | L1: 306 | L1: 213 | 1.087 | 674 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |
| P _R : 0% Q _c : +5% | L1: 235 | L1: 309 | L1: 213 | 1.091 | 700 | 9000 |
| | L2: -- | L2: -- | L2: -- | -- | | |
| | L3: -- | L3: -- | L3: -- | -- | | |

| | | | | | |
|-----------|---|----------------|--------------|----------------|---|
| 8.3(5.6) | TABLE: Connection conditions and synchronization (Reconnection) | | | | P |
| Condition | Measurement | | Limitation | | |
| | Reconnection | Delay time [s] | Reconnection | Delay time [s] | |
| f<47.45Hz | No | -- | No | ≥60 | |
| f≥47.55Hz | Yes | 216.3 | Yes | ≥60 | |
| f>50.15Hz | No | -- | No | ≥60 | |
| f≤50.05Hz | Yes | 80.1 | Yes | ≥60 | |
| U<0.84Un | No | -- | No | ≥60 | |
| U≥0.86Un | Yes | 72.8 | Yes | ≥60 | |
| U>1.11Un | No | -- | No | ≥60 | |
| U≤1.09Un | Yes | 60.4 | Yes | ≥60 | |
| Note(s): | | | | | |


Appendix table 2 -Photos of the product




Overview



Overview -



Inside view



Inside view

